

GARNETT CIRCLE CONNECTION SCHEDULE

UNIT	CONNECTION AT MAIN	LATERAL TERMINATION	LENGTH
41	SAN 31+15.80, 16.21' LT.	31+15.80, 40.05' RT.	56.26
	ST 31+10.80, 20.00' LT.	31+10.80, 40.04' RT.	60.04
	WAT 31+25.80, 49' RT.	31+25.80, 20.49' LT.	19.56
50	SAN 31+36.15, 18.18' LT.	31+36.16, 40.00' LT.	23.82
	ST 31+31.15, 20.00' LT.	31+31.16, 40.00' LT.	20.00
	WAT 31+46.16, 20.49' RT.	31+46.16, 40.00' LT.	60.49
40	SAN 31+85.80, 16.12' LT.	31+85.80, 40.04' LT.	56.16
	ST 31+80.80, 20.00' LT.	31+80.80, 40.04' RT.	60.04
	WAT 31+95.80, 20.49' RT.	31+95.80, 40.04' RT.	19.55
51	SAN 32+06.15, 16.09' LT.	32+06.16, 40.00' LT.	23.91
	ST 32+01.15, 20.00' LT.	32+01.16, 40.00' LT.	20.00
	WAT 32+16.16, 20.49' RT.	32+16.16, 40.00' LT.	60.49
39	SAN 32+50.80, 20.00' LT.	32+50.80, 40.03' RT.	60.03
	ST 32+45.80, 20.49' RT.	32+45.80, 40.03' RT.	19.54
	WAT 32+76.15, 16.00' LT.	32+76.16, 40.00' LT.	24.00
52	SAN 32+71.15, 20.00' LT.	32+71.16, 40.00' LT.	20.00
	ST 32+91.16, 20.49' RT.	32+91.16, 40.00' LT.	60.49
	WAT 32+91.16, 20.49' RT.	32+91.16, 40.00' LT.	60.49

GARNETT CIRCLE WATER MAIN FITTING SCHEDULE

UNIT	CONNECTION AT MAIN	LATERAL TERMINATION	LENGTH
38	SAN 33+25.80, 15.96' LT.	33+25.80, 40.01' RT.	55.98
	ST 33+15.80, 20.00' LT.	33+15.80, 40.02' RT.	60.02
	WAT 33+35.80, 20.49' RT.	33+35.80, 40.01' RT.	19.52
53	SAN 33+49.00, 15.98' LT.	33+49.00, 40.00' LT.	24.04
	ST 33+54.00, 20.00' LT.	33+54.00, 40.00' LT.	20.00
	WAT 33+39.01, 20.49' RT.	33+39.01, 40.00' LT.	60.49
37	SAN 33+88.65, 15.95' LT.	33+88.65, 40.00' RT.	55.95
	ST 33+98.66, 20.03' LT.	33+98.65, 40.00' RT.	60.03
	WAT 33+78.65, 20.49' RT.	33+78.65, 40.00' RT.	19.51
54	SAN 34+18.99, 15.94' LT.	34+18.99, 40.00' LT.	24.06
	ST 34+24.00, 20.00' LT.	34+24.00, 40.00' LT.	20.00
	WAT 34+09.00, 20.49' RT.	34+09.00, 40.00' LT.	60.49
36	SAN 34+58.65, 15.93' LT.	34+58.65, 40.00' RT.	55.93
	ST 34+63.65, 20.00' LT.	34+63.65, 40.00' RT.	60.00
	WAT 34+48.65, 20.49' RT.	34+48.65, 40.00' RT.	19.51
55	SAN 34+89.00, 15.93' LT.	34+89.00, 40.00' LT.	24.07
	ST 34+94.00, 20.00' LT.	34+94.00, 40.00' LT.	20.00
	WAT 34+79.01, 20.49' RT.	34+79.01, 40.00' LT.	60.49
35	SAN 35+28.65, 15.92' LT.	35+28.65, 40.00' RT.	55.92
	ST 35+33.65, 20.00' LT.	35+33.65, 40.00' RT.	60.00
	WAT 35+18.65, 20.49' RT.	35+18.65, 40.00' RT.	19.51
56	SAN 35+82.75, 15.91' LT.	35+82.75, 40.00' LT.	24.09
	ST 35+77.77, 20.00' LT.	35+77.77, 40.00' LT.	20.07
	WAT 35+91.15, 20.49' RT.	35+91.16, 40.00' LT.	60.49

STORM SEWER
 REFER TO GENERAL NOTES SHEET 5 FOR GENERAL NOTES.
 ALL RCP PIPE SHALL BE CLASS 4 PER ODOT 706.02
 ALL HDPE PIPE SHALL BE SMOOTH LINED PER ODOT 707.33
 ALL PVC PIPE SHALL BE SDR 35 PER ODOT 707.45

- LEGEND**
 SEE GENERAL LEGEND, SHEET 4
- PROPOSED ROLLED CURB AND GUTTER
 - PROPOSED WALK
 - PROPOSED WALK BY OTHERS
 - PROPOSED WATER LATERAL
 - PROPOSED SANITARY LATERAL
 - PROPOSED STORM LATERAL
 - PROPOSED WATER MAIN
 - PROPOSED SANITARY MAIN
 - PROPOSED STORM MAIN
 - PROPOSED C/L OF CONSTRUCTION
 - PROPOSED C/L OF RIGHT OF WAY
 - PROPOSED MONUMENT BOX
 - PROPOSED BOTTOM OF FOOTER ELEVATION


PROPOSED STRUCTURE TABLE

Structure Name	Structure Details
CB-AZ	ODOT CB 3 STA. 32+86.16, -13.00 Lt. RIM = 1079.17 12" Concrete Pipe*INV (W)=1076.41 12" Concrete Pipe*INV (E)=1076.41
CB-BA	ODOT CB 3 STA. 32+86.16, 13.00 Rt. RIM = 1079.17 12" Concrete Pipe*INV (E)=1076.67
CB-BB	ODOT CB 3A STA. 33+95, -13.00 Lt. RIM = 1080.34 12" PVC INV (W)=1077.03 12" PVC Pipe INV (E)=1077.03

NOTE:
 ANY SERVICE LATERAL CROSSING WATER MAIN SHALL MAINTAIN 18" MINIMUM CLEARANCE.
 ALL WATER MAIN PIPE JOINTS WITHIN AREAS OF FILL MUST BE RESTRAINED.

REVISIONS

REV.	DATE	DESCRIPTION
1	06/02/14	REVISED PER LOCAL AGENCY COMMENTS
2	06/27/14	REVISED PER LOCAL AGENCY COMMENTS
3	07/18/14	REVISED PER LOCAL AGENCY COMMENTS
4	07/25/14	REVISED PER LOCAL AGENCY COMMENTS
5	08/01/14	MILLER PARCEL UTILITY UPDATE
6	08/05/14	COMMENTS FOR GRADING APPROVAL
7	08/20/14	REVISED PER LOCAL AGENCY COMMENTS
8	08/22/14	SANITARY REVISION MH 300-302
9	09/12/14	REVISED PER LOCAL AGENCY COMMENTS



PLAN AND PROFILE
 THE PRESERVE AT MILLER'S FARM
 SE CORNER OF SR 18 AND MEDINA LINE RD
 COPLEY, OHIO 44321
GARNETT CIRCLE

ISSUED FOR:

PERMIT	06-02-14
BID	06-02-14
CONSTRUCTION	09-16-14
RECORD	-

PROJECT MANAGER MAL **DESIGNER** KB

JOB NO.
2013258.00
44/81